LA-UR -85-1602

Los Alamos National Laboratory is operated by the University of California for the United States Department of Energy under contract W-7405-ENG-36

LA-UR--85-1602

DE85 012674

TITLE: GAMMA-RAY LINE INTENSITIES FOR DEPLETED URANIUM


DISCLAIMER

AUTHOR(S) C.E. Moss

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

SUBMITTED TO. International Conference on Nuclear Data for Basic and Applied Sciences
Santa Fe, New Mexico

May 13-17, 1985





By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes

The Los Alamos National Caboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy



GAMMA-RAY LINE INTENSITIES FOR DEPLETED URANIUM

CALVIN E. MOSS
Los Alamos National Laboratory, Los Alamos, New Mexico, USA

Abstract Measurements of the gamma-ray line intensities from depleted uranium allowed us to determine which of two conflicting previous experiments was correct. For the 1001-keV line we obtained a branching ratio of 0.834 ± 0.007, in good agreement with one of the previous experiments. A table compares our intensities for several lines with those obtained in previous experiments.

INTRODUCTION .

The gamma-ray line intensities from depleted uranium are necessary for assaying material in nuclear safeguards and for calculating the gamma-ray flux from objects containing depleted uranium. Most of the gamma rays are produced by ²³⁴MPa and ²³⁴Pa in equilibrium with ²³⁸U (Fig. 1). For the strong 1001-keV from ²³⁴MPa, the Table of Isotopes¹ and the Nuclear Data Sheets³ quote a branching intensity of 0.59% based on a 1963 reference.³ A

$$0^{+}$$
238
92^U146 $\%$ $\alpha = 100$

$$\frac{\text{(O^-)}}{4^{(+)}} \% \text{IT=0.13} \% \beta^- = 99.87$$

$$\frac{234}{91} \text{Pa}_{143} \% \beta^- = 100$$

FIGURE 1 Part of the decay chain for 200U.

1971 report from the Lawrence Livermore National Laboratory gives 0.828%. Some difficulties in obtaining agreement between calculated and measured fluxes from objects containing depleted uranium prompted us to remeasure the intensities of lines from depleted uranium.

EQUIPMENT AND METHODS

For the measurements, we used three high-purity germanium detectors, five samples and two distances in many combinations. The resolutions (full width at half maximum) and the efficiencies (at 1332 keV relative to the efficiency of a 7.62 cm long by 7.62 cm diameter Nal(Tl) detector) of the three detectors were 1.98 keV and 19.8%, 1.90 keV and 11.3%, and 1.73 keV and 31.7%. Four of the samples were disks with the following masses: 0.5 g, 5.8 g, 11.3 g, and 22.4 g. The fifth sample was a 270.0-g foil 15.9 cm long and 10.8 cm wide. Each sample contained 0.997% 23.0 by weight. The two distances between the source and the detector were 25 cm and 100 cm. An 8192-channel analyzer acquired the pulse-height distributions.

To calibrate the efficiency of the system we used a radioactive source from the US National Bureau of standards (NBS) containing 128Sb, 184Eu, and 188Eu. The uncertainties in most of the line intensities were less than 0.7%. We also compared several commercial sources such as 89 and 60Co with larger uncertainties to the NBS source to verify that there were no gross inconsistencies. Some calibration measurements were made with just the NBS source present; for others, the NBS source and the uranium sample were both present and located at the same distance.

Analysis of the measurements required the determination of peak areas. A program called FiTEKs determined some of the peak areas by fitting a Gaussian function with tails to the peaks. Other peak areas were determined in the pulse-height analyzer by subtracting a straight-line approximation for the continuum under each peak. Separate background measurements were used to correct all peak areas.

Two methods were used to determine an efficiency curve from the efficiency calibration pusk areas. The first method involved fitting the efficiency points with the function

$$\ln E_p = \sum_{i=1}^{NMAX} A_i (\ln E)^{i-1}$$

where $E_p = efficiency$, $A_i = coefficient$, E = energy in keV, and NMAX = maximum number of parameters, usually eight. The second method was simply manually drawing a curve through the efficiency points.

RESULTS

Among the many gamma-ray lines from depleted uranium (Fig. 2) we chose the five lines with energies 742, 766, 786, 946, and 1001 keV for analysis. These lines are the strongest ones in the region where our efficiency curves are most accurate. The Table shows that our values are in good agreement

with those of Ref. 4. Our value of 103.7 \pm 0.9 photons/s/g of ²³⁸U for the 1001-keV line corresponds to a ³³⁴MPa branching ratio of 0.834 \pm 0.007; the value in Ref. 4 is 0.828 \pm 0.008.

We have calculated recommended values for eight strong lines (last column of the Table). These values are averages weighted by the square of the uncertainties from three sources: Ref. 2 normalized, Ref. 4, and the present work. The weighted average of the value of 103.0 ± 1.0 from Ref. 4 and the value of 103.7 ± 0.9 for the 1001-keV line is 103.4 ± 0.7 . We used this value to normalize the values in Ref. 2. The uncertainties in column two of the Table include a 14% uncertainty in the overall normalization added by Ellis-Akovali; we omitted this uncertainty in our weighting procedure. Values for lines not shown in the Table can be calculated with a similar weighting procedure.

TABLE Specific activities of lines from depleted uranium.

Energy (keV)	Nuclear Data Sheets ^a	Livermoreb	Present Work	Recommended
258	7.1 ± 1.0	9.1 ± 0.3		9.4 ± 0.2
742	7.4 ± 1.0	11.8 ± 0.2	12.1 ± 0.7	11.65 ± 0.18
766	25 ± 4	38.9 ± 0.4	41.4 ± 0.9	39.1 ± 0.4
786	4.5 ± 0.6	6.84 ± 0.14	6.8 ± 0.5	6.73 ± 0.12
946	2.8 ± 1.1	4.41 ± 0.09	4.2 ± 0.5	4.40 ± 0.09
1001	73 ± 10	103.0 ± 1.0	103.7 ± 0.9	103.4 ± 0.7
1738	1.8 ± 0.3	2.64 ± 0.03		2.63 ± 0.03
1831	1.4 ± 0.2	2.18 ± 0.02		2.16 ± 0.02

aRef. 2.

ACKNOWLEDGEMENTS

G. P. Estes performed the Monte Carlo calculations which convinced us of the need for these measurements. E. J. Dowdy, M. C. Lucas, J. M. Malanify, and E. A. Plassmann provided support and encouragement.

REFERENCES

- 1. C. M. Lederer and V. S. Shirley (Eds.), Table of Isotopes, 7th ed. (Wiley New York, 1978).
- 2. Y. A. Ellis-Akovali, Nucl. Data Sheets <u>40</u>, 523 (1983)
- S. Bjornholm and O. B. Nielsen, Nucl. Phys. 42, 642 (1963).
- 4. R. Gunnink and J. F. Tinney, "Analysis of Fuel Rods by Gamma-Ray Spectroscopy," Lawrence Livermore National Laboratory report UCRL-51086 (1971).
- 5. Hans Stoeffi, private communication.

bRef. 4.




FIGURE 2 Pulse-height distribution from the 270.0 g sample of depleted uranium at 25 cm.